

The Following information regarding this incident has been reported:

Reporting Date: 10/24/2019 11:30:45 AM

Incident Date: 10/23/2019 @ 9:20 p.m.

Reported By: Meredith Allen, Sr. Director

Utility Name: PG&E

Phone Number: (415)828-5765

Email Address: MEAe@pge.com

Incident Location: Near Kincade Rd and Burned Mountain Rd Cloverdale, Sonoma

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? No (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? Yes

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Geysers #9 - Lakeville
- Voltage (KV): 230
- Customer's Facilities:

DigIn Information:

- Excavator Name:

- Contact:

- Phone: (____)____ - _____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.

- Service Restored: @ 00:00 a.m.

Summary: At approximately 2120 hours on October 23, 2019, PG&E became aware of a Transmission level outage on the Geysers #9 Lakeville 230kV line when the line relayed and did not reclose. At approximately 0730 hours on October 24, 2019, a responding PG&E Troublemán patrolling the Geysers #9 Lakeville 230 kV line observed that CAL FIRE had taped off the area around the base of transmission tower 001/006. On site CAL FIRE personnel brought to the Troublemán's attention what appeared to be a broken jumper on the same tower. PG&E is reporting this incident under the Media Criterion. This information is preliminary.